Power Flow Analysis of IEEE 14 Bus System Using Matlab

Mr. Sanjib Hazarika Assistant Professor, Dept of EE

GIMT, Azara, India

Abstract- For proper planning and operation of power system and economic scheduling of generating units, power flow analysis plays a vital role. It is performed to have clear knowledge regarding bus voltage magnitude and angle and line flows. A number of methods are being used all over the world for power flow analysis. Newton Raphson method, Gauss Seidal method, fast decoupled load flow methods are a few to name. Now days, various soft computing techniques are adopted by researchers as well as practicing engineers for load flow analysis to cater various needs of the research institutes and the utilities. Every method has got advantages as well as disadvantages.

The objective of this paper is to develop an user friendly software to perform load flow analysis for IEEE 14 bus system. The software will be helpful for researchers, practicing engineers, students of power system of various levels to carry out power flow quickly and efficiently as per their requirement. The software is developed using MATLAB programming.

I. INTRODUCTION

Line flow analysis (LFA) is used to make sure that electrical power transfer from generator stations to consumers end through the grid system in reliable and economical form. Conventional techniques for line flow analysis problem are iterative mathematical method like the Newton-Raphson (NR) or the Gauss-Seidel (GS) methods. An engineer is always concerned about economic condition of the system operation. For the mighty interconnected grid system, the power shortage results continuous hike in prices. Thus, it is the priority of engineer to control this continuous hike. Another major problem is economic load dispatch in an optimized manner as it is directly related with load demands. For economically optimized operation of interconnected grid system modern system theory and optimization techniques are being applied with the optimized generation cost function. Through the line flow study, the voltage magnitude and angle at each bus under the steady state can be obtained.

Load flow studies are undertaken to determine

i) The bus voltage magnitude and system voltage profile.ii) The line flows.

iii) The effect of change in circuit configurations and inclusion of new circuit elements on system loading.

iv) The effect of temporary loss of transmission capacity and generations on supplied load and accompanied effects.

v) The effect of in-phase and quadrature boost voltages on system loading data obtained from load flow can be further useful for economic system operation and system transmission loss minimization.

II. POWER FLOW ANALYSIS

A bus is a node at which one or many lines, one or many loads and generators are connected. In a power system each node or bus is associated with 4 quantities, such as magnitude of voltage, phage angle of voltage, active or true power and reactive power in load flow problem two out of these 4 quantities are specified and remaining 2 are required to be determined through the solution of equation. Depending on the quantities that have been specified, the buses are classified into 3 categories. Buses are classified according to which two out of the four variables are specified

III. CLASSIFICATION OF BUSES

In an electrical power system all the buses constitutes of four variables, which are voltage magnitude, voltage phase angle, active power and reactive power in line flow.

For power flow solution out of these four variables, two are made constant and two are treated as variable. All the buses are categorised on the basis of the constant parameters.

- 1) **Load bus**: At this bus, the real and reactive powers are specified. Voltage and phase angles are not defined. No generators are attached with this bus.
- 2) Generator bus: This bus is also called as voltage controlled bus. Here the voltage magnitude corresponding to the generator voltage and real power (Pg) are specified. Reactive power generation (Qg) and voltage phase angle are the unknown parameter for line flow calculations.

IJSART – Volume 5 Issue 5 – MAY 2019

3) **Slack Bus**: It is also known as Swing Bus. In this bus it is assumed that voltage magnitude and phase angle is known parameters. The real power generated (Pg) and the reactive power generated (Qg) are considered as unknown parameter.

Newton Raphson Method

Newton Raphson method is the best opted method for solving non-linear load flow equations as it gives better convergence speed as compare to other load flow methods. The number of iterations involved in Newton Raphson method is independent of number of buses considered, hence power flow equations can be solved just in few iterations. Newton Raphson method transforms the set of non-linear equations into a set of linear equations which approach to the original solution efficiently.

The Newton Raphson method is the most robust power flow algorithm used in practice. However, drawback of this method lies in the fact that the terms of the Jacobian matrix must be recalculated and then the entire set of linear equations must also be solved in each iteration.



Fig 1: Flowchart of Newton-Raphson Method

V. OBJECTIVES OF THE PAPER

This paper aims to investigate the effect of applying Newton Raphson method in calculation of power flow in a IEEE 14 bus system. The aim is to investigate the real power loss and reactive power loss and to plot for different branches. Addition to that, the paper also aims to investigate the voltage profile at different nodes by calculating voltage magnitude and angle for different nodes. It Aims to analyse the scenario of real power loss and reactive power loss for all the mentioned cases.

VI. RESULTS AND ANALYSIS

A IEEE 14 bus system with 11 loads and 3 transformers have been chosen for analysis. The detail description of the system is given below.

rusic it system comiguration				
14				
5				
11				
1				
20				
3				

Table 1: System Configuration

The Bus data of the IEEE 14 bus system with Power generation and load details are given in Table 2.

Table 2: Bus data of 14 bus system

Bus Data of IEEE 14 Bus System						
Due	Volt	Angle	Gene	ration	ما	ad
BUS	pu	Deg	P(MW)	Q(MVAR)	P(MW)	Q(MVAR)
1	1	0.06	0.000*	232.39	-16.55	-
2	1.045	-4.983	40	43.56	21.7	12.7
3	1.01	-12.725	0	25.08	94.2	19
4	1.018	-10.313	-	-	47.8	-3.9
5	1.02	-8.774	-	-	7.6	1.6
6	1.07	-14.221	0	12.73	11.2	7.5
7	1.062	-13.36	-	-	-	-
8	1.09	-13.36	0	17.62	-	-
9	1.056	-14.939	-	-	29.5	16.6
10	1.051	-15.097	-	-	9	5.8
11	1.057	-14.791	-	-	3.5	1.8
12	1.055	-15.076	-	-	6.1	1.6
13	1.05	-15.156	-	-	13.5	5.8
14	1.036	-16.034	-	-	14.9	5
		Total:	272.39	82.44	259	73.5

IJSART – Volume 5 Issue 5 – MAY 2019

With this existing system load flow analysis has been carried out and voltage magnitude and angles at different points have been calculated. The real and reactive power injections to different nodes have been calculated using Newton-Raphson method and are summarised in Table 3.

Power injection Details							
Dronoh	From	То	Injection	from bus	Injectio	on to bus	
DI dI IUI	Bus	Bus	P (MW)	Q (MVAR)	P (MW)	Q (MVAR)	
1	1	2	156.88	-20.4	-152.59	27.68	
2	1	5	75.51	3.85	-72.75	2.23	
3	2	3	73.24	3.56	-70.91	1.6	
4	2	4	56.13	-1.55	-54.45	3.02	
5	2	5	41.52	1.17	-40.61	-2.1	
6	3	4	-23.29	4.47	23.66	-4.84	
7	4	5	-61.16	15.82	61.67	-14.2	
8	4	7	28.07	-9.68	-28.07	11.38	
9	4	9	16.08	-0.43	-16.08	1.73	
10	5	6	44.09	12.47	-44.09	-8.05	
11	6	11	7.35	3.56	-7.3	-3.44	
12	6	12	7.79	2.5	-7.71	-2.35	
13	6	13	17.75	7.22	-17.54	-6.8	
14	7	8	0	-17.16	0	17.62	
15	7	9	28.07	5.78	-28.07	-4.98	
16	9	10	5.23	4.22	-5.21	-4.18	
17	9	14	9.43	3.61	-9.31	-3.36	
18	10	11	-3.79	-1.62	3.8	1.64	
19	12	13	1.61	0.75	-1.61	-0.75	
20	13	14	5.64	1.75	-5.59	-1.64	

Table 3: Power Injection of 14 bus system

.

The real power loss have been calculated and it is found that the real power loss is highest at branch1 (line 1-2).



Fig 1: Real power loss (MW)



Fig 2: Reactive power loss (MVAR)

The real and reactive power losses at different buses have been calculated and are summerised in table 4. It is seen from the investigation that, the real power loss will be highest in line 1-2 and reactive power loss is also highest in line 1-2.

Loss Analysis					
	From	To	Losses		
Branch	Bus	Bus	P (MW)	Q (MVAR)	
1	1	2	4.298	13.12	
2	1	5	2.763	11.41	
3	2	3	2.323	9.79	
4	2	4	1.677	5.09	
5	2	5	0.904	2.76	
6	3	4	0.373	0.95	
7	4	5	0.514	1.62	
8	4	7	0	1.7	
9	4	9	0	1.3	
10	5	6	0	4.42	
11	6	11	0.055	0.12	
12	6	12	0.072	0.15	
13	6	13	0.212	0.42	
14	7	8	0	0.46	
15	7	9	0	0.8	
16	9	10	0.013	0.03	
17	9	14	0.116	0.25	
18	10	11	0.013	0.03	
19	12	13	0.006	0.01	
20	13	14	0.054	0.11	
Total			13.39	54.54	

Table 3: Power Injection of 14 bus system	Table 3:	Power	Injection	of 14	bus system
---	----------	-------	-----------	-------	------------

	Minimum	1	Maximum	
Parameters	Value	At	Value	At bus
Voltage Magnitude (PU)	1.01	Bus 3	1.09	Bus 8
Voltgae Angle (Deg)	-16.03	Bus 14	0	Bus 1
P Loss (MW)			4.3	Line 1-2
Q Loss (MVAR)			13.12	Line 1-2

VI. CONCLUSION

The real power variations and voltage profile can indicate the need of improving in respect to voltage and load requirement. Loss optimization can also be possible with the use of corrective measures. The real power loss and reactive power loss in maximum in line 1-2. Similarly the voltage magnitude became highest in Bus 8.

REFERENCES

- N. Usha, Simulation results of eight bus system using pushpull inverter base STATCOM, Journal of Theoretical and Applied Information Technology, 2005 - 2009 JATIT.
- [2] C. R. Feurte Esquivel and E. Acha 'A Newton-type algorithm for the control of power flow in electrical power networks," IEEE Transactions on Power Systems, Vol.12,Nov.1997.
- [3] Rohit Kapahi, Load flow analysis of 132 KV substation using ETAP software, International Journal of Scientific & Engineering Research Volume 4, Issue 2, February-2013,ISSN 2229-5518
- [4] A. J. Wood, B. F. Wollenberg. Power Generation Operation and Control. 2nd ed. John Willey & Sons Inc
- [5] D.I.Sun, B.Ashley, B.Brewer, A.Hughes and W.F.Tinney, "Optimal Power Flow by Newton Approach", *IEEE Transactions on Power Apparatus and systems*, vol.103, No.10, 1984, pp2864-2880.
- [6] Mr. Rudresh. B. Magadum, Mr. Tejaswi. M. Timsani, "Minimization of Power Loss in Distribution Networks by Different Technology".,International Journal of Scientific & Engineering Research Volume 3, Issue 5, 2012
- [7] P. V. V. Rama Rao and S. Sivanagaraju, "Radial istribution NetworkReconfiguration for Loss Reduction and Load Balancing using Plant Growth Simulation

Algorithm", International Journal on Electrical Engineering and Informatics - Volume 2, Number 4, 2010